2-conductor lighting connector; push-button on lighting side; Lighting side: for all conductor types; Inst. side: for solid conductors; 224 Series; max. 2.5 mm²; Surrounding air temperature: max 60°C; 2,50 mm²; white




https://www.wago.com/224-112





Color: white



Dimensions in mm

N.	_	ı	_	_
N	0	τ	е	S


Safety information in grounded power lines

## Electrical data

Ratings per IEC/EN	
Ratings per	EN 60664
Nominal voltage (II/2)	400 V
Rated surge voltage (II/2)	4 kV
Rated current	24 A
Legend (ratings)	(II / 2) ≙ Overvoltage category II / Pollution degree 2

#### Connection data

https://www.wago.com/224-112





Connection 1	
Connection type 1	Installation side
Connection technology	PUSH WIRE®
Actuation type	Push-in
Connectable conductor materials	Copper Aluminum
Connectable conductor materials (note)	Terminating Aluminum Conductors WAGO spring clamp terminal blocks are suitable for solid aluminum conductors up to 4 mm²/12 AWG if WAGO "Alu-Plus" Contact Paste <a href="https://www.wago.com/249-130">249-130</a> is used for termination.
	"Alu-Plus" Contact Paste Advantages:
	<ul> <li>Automatically destroys the oxide film during clamping.</li> <li>Prevents fresh oxidation at the clamping point.</li> <li>Prevents electrolytic corrosion between aluminum and copper conductors (in the same terminal block).</li> <li>Provides long-term protection against corrosion.</li> </ul>
	Using terminal blocks with CAGE CLAMP® Spring Pressure Connection Technology, aluminum conductors must first be cleaned with a blade and then immediately be inserted into the clamping units filled with "Alu-Plus" Contact Paste.
	For spring clamp connections with PUSH WIRE® connection technology, <b>WAGO recommends that the aluminum conductor first be cleaned</b> and then immediately inserted into the clamping unit filled with "Alu-Plus" contact paste.
	It is also possible to apply WAGO "Alu- Plus" <b>additionally</b> on the whole surface of the aluminum conductor before termi- nation.
	Please note that the nominal currents must be adapted to the reduced conduc- tivity of the aluminum conductors:: 2.5 mm <sup>2</sup> = 16 A 4 mm <sup>2</sup> = 22 A
Solid conductor	1 2.5 mm² / 16 14 AWG
Strip length	9 11 mm / 0.35 0.43 inches
Wiring direction	Side-entry wiring

Connection 2	
Connection type 2	Lighting side
Connection technology 2	CAGE CLAMP®
Number of connection points 2	1
Solid conductor 2	0.5 2.5 mm² / 20 14 AWG
Fine-stranded conductor 2	0.5 2.5 mm² / 20 16 AWG

https://www.wago.com/224-112



#### Physical data 9.5 mm / 0.374 inches Width Height 15.5 mm / 0.61 inches Depth 20.5 mm / 0.807 inches

Material data	
Note (material data)	Information on material specifications can be found here
Color	white
Fire load	0.047 MJ
Weight	2.1 g

Environmental requirements	
Continuous operating temperature	105 °C

Commercial data	
Product Group	7 (Push Wire Conn.)
eCl@ss 10.0	27-14-11-03
eCl@ss 9.0	27-14-11-03
ETIM 8.0	EC000447
ETIM 7.0	EC000447
PU (SPU)	1000 (100) pcs
Packaging type	Box
Country of origin	CH
GTIN	4044918583596
Customs tariff number	85369010000

## Approvals / Certificates

## General approvals











Approval	Standard	Certificate Name
CSA DEKRA Certification B.V.	C22.2	1053495
UL UL International Germany GmbH	UL 486C	E69654
UL UL International Germany GmbH	EN 60998	CCA-2617-A1
UL UL International Germany GmbH	EN 60998	D-05895-A1 (EN60998-1 EN60998-2-2)
VDE VDE Prüf- und Zertifizie- rungsinstitut	EN 60998	40022792

## Declarations of conformity and manufacturer's declarations

Approval	Standard	Certificate Name
EU-Declaration of Conformity WAGO GmbH & Co. KG	-	-
UK-Declaration of Conformity WAGO GmbH & Co. KG	-	-

https://www.wago.com/224-112



## Approvals for marine applications










VERITAS	arrando.	
Approval	Standard	Certificate Name
ABS American Bureau of Ship- ping	-	18-HG1755093-PDA
BV Bureau Veritas S.A.	EN 60998	11914/D0 BV
DNV GL Det Norske Veritas, Ger- manischer Lloyd	EN 60998	TAE000015T
LR Lloyds Register	EN 60998	LR22207029TA

# Downloads Environmental Product Compliance Compliance Search Environmental Product Compliance 224-112

Documentation			
Bid Text			
224-112	19.02.2019	xml 3.46 KB	<u>↓</u>
224-112	21.02.2019	docx 15.55 KB	$\downarrow$



1 Compatible Products	
1.1 Optional Accessories	
1.1.1 Tool	

https://www.wago.com/224-112



#### 1.1.1.1 "Alu-Plus" contact paste



<u>Item No.: 249-130</u>

Syringe; Contents: 20 ml Alu-Plus contact paste

#### **Installation Notes**

#### **Conductor termination**







Strip conductor to 9  $\dots$  11 mm (0.35  $\dots$  0.43 inch).

#### Conductor termination





To connect: Press button fully, insert stripped conductor into square entry and release.



To remove: Press button and withdraw conductor.

#### **Conductor termination**





To connect: Insert stripped solid conductor into circular entry and push until it hits the backstop.



To remove: Hold conductor to be removed and twist alternately left and right while slightly pulling the connector.

#### Testing



Testing via separate test ports.

Subject to changes. Please also observe the further product documentation!

Current addresses can be found at::  $\underline{www.wago.com}$ 

Page 5/5 Version 25.03.2023